

# DEPARTMENT OF TRANSPORTATION

## STATE OF GEORGIA

### INTERDEPARTMENTAL CORRESPONDENCE

**FILE** NH000-0575-01(028), Cherokee Co.  
PI No. 713640  
Br. No. 41 - I-575 over Towne Lake Pkwy

**OFFICE** Materials and Research  
Forest Park, GA

**DATE** January 15, 2010

**FROM** *T.S. For*  
Georgene M. Geary, P. E., State Materials and Research Engineer

**TO** Darryl VanMeter, State Innovative Program Delivery Engineer  
Attn: John Hancock

**SUBJECT** Review of Consultant's Bridge Foundation Investigation  
I-575 over Towne Lake Parkway - Bridge No. 41

As requested, we have reviewed the Bridge Foundation Investigation that was written on November 20, 2009 by Professional Services Industries, Inc. of Atlanta, Georgia. Our comments are as follows:

**Project Number** The correct project number for this report is NH000-0575-01(028), Cherokee Co. and the correct PI No. is 713640. This should be corrected on all pages throughout the report reflecting the project number.

**Elevations** We recommend lowering the estimated tip elevation for bent 2 to 849, raising the minimum tip elevation for bent 3 to 868, and estimated tip for bent 4 to 857.

If additional information is needed, please contact Neoma Cole of the Geotechnical Engineering Bureau at 404-363-7546.

GMG: NKC

Copy: - - - - -  
- - - - -  
- - - - -  
- - - - -

Paul Liles, P. E., State Bridge and Structural Design Engineer