

DEPARTMENT OF TRANSPORTATION

STATE OF GEORGIA

INTERDEPARTMENTAL CORRESPONDENCE

FILE NH000-0073-03 (242) Cobb
PI No. 714130

OFFICE Materials and Research
Forest Park, Ga.

DATE February 22, 2010

FROM *D.M. Geary*
Georgene M. Geary, P. E., State Materials and Research Engineer

TO Mr. Darryl D. Van Meter, P.E., State Innovative Program Delivery Engineer
Attn: John Hancock

SUBJECT Review of Consultant's Tie-Back Wall Foundation Investigation Report
I-75 Reversible Lanes Bridge under Allgood Road Northwest Corridor
Project

As requested, we have reviewed the Tie-Back Wall Foundation Report that was written on December 4, 2009 by Wilmer Engineering, Inc of Atlanta, Georgia. Our comments are as follows:

County Name Please include the county name after the project number

Recommendations Please revise cohesion value to 50 psf.

If additional information is needed, please contact Marc A. Payne of the Geotechnical Engineering Bureau at 404-363-7546.

GMG: MAP

Copy: Paul Liles, P. E., State Bridge and Structural Design Engineer